

Facility Preventive Maintenance Log

A/H, Took Hot Water Pump out
Took to Pearson Pump. Date/1-6-04^{out}


No-#E 150782C1E2LOA
54845 Date 1-6-04ⁱⁿ
4:30 PM

2nd Floor 1-6-04
L/C Charged Out Contractor
Starter for Air Handler No 5

Charged out Contractor^{Starter} for Air
Handler A+A 1st Floor Auto
body. 1-6-04

Charged Belts on A.H. Handler
A+A 2nd Floor - 1-20-04

A+A 1st Floor Auto bay - New
Control Valve Installed on
Air Handler



2-17-04 Installed New Contactor
for A+A second floor Air Handler

2-18-04 Installed New Contactor
A+A 1st Floor Hot Water Pump

3-23-04 Installed New Door Closer
L/C 2nd Floor Right Hand.

5-13-04. All Air Handler Coils
Cleaned + Filters changed.

Clean Air Handler Coils + Checked
belts + Greased - motors 5/10/04
Through 5/14/04
All Done.

6/22/04 Hot Water Pump for
H/S Building - Rebuilt + Installed.
(Repair - Reservoir pump)

8-3-04 Changed all air Handler
Filters + Greased motors

7-7-04. all VAV Filters
Have been Changed.

Installed New Chiller & 3 New
Cooling Towers. Oct-

Emg Gen - Oiled Charged & Oil
Filters Oct - 04

P.M.S ON Boilers Done

OCT-21-22-04

12-1-04 Installed new Hot water
Heater, 2nd Floor. 6 gal.

1-12-05 Dogwood Building
Repairing all Emerg Lights
Batt operated type.
Complete.

1-31-05 Emg Lights Repair
Complete.

2-24-05 Change mag starter to Compressor
in LC building. mech Room.

3-7-8-9- Compressors, Change Oil
& Check belts & Greased motors

(05)

4-4-05 / Installed new Compressor
for Heat Pump Child Care
Back Unit No 1

ALL Air Handlers Coils Cleaned Belts (New
Filters)
Charged if needed & Checked & Greased
5-18-05